

FAQ

"Do we have to submit all the documents again each time? The stand set-up has not changed from previous fair events."

→ Yes.

In principle, the documents submitted always apply only to the respective trade fair appearance and must be submitted again for each subsequent one.

"Are upright-hanging constructions permitted?"

→ No.

Standing-hanging constructions are generally not permitted.

"We are building a system stand, do we still need a proof of stability?"

→ Yes.

The possibly required proof of stability refers to the individual construction regardless of the building materials used. If there is a system static of the manufacturer for recurring superstructures, this can of course be used as proof of stability in the case of identical construction.

„We are building an exhibition stand that has already been constructed identically at another trade fair. Do we still need a mathematical proof of stability?"

→ Yes,

if it is a so-called special construction. However, the approval documents (with complete documentation on stability) can be attached to the documents to be submitted.

"We are building an exhibition stand that has already been constructed identically at another trade fair. We have an old static calculation for this. May we use this calculation again as proof of stability?"

→ Depends on the statics.

Depending on the information provided by the structural engineer in the structural analysis, it may be explicitly valid only for a specific trade fair event or it may have been prepared as a type static analysis.

"Can we as stand constructors also carry out the necessary structural safety verifications ourselves?"

→ Yes.

However, the responsible structural engineer must sign the verifications and be liable for them. Depending on the complexity of the verifications, however, it is strongly recommended to commission a qualified structural engineer to prepare the verifications.

"Is it possible to anchor the stand construction in the hall floor?"

→ Yes, but not in all halls.

Please contact Messe Essen in this regard. The anchorages in the hall floor must be applied for there and will also be approved by the persons responsible there.